

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

ProSoft Technology Inc.

9201 Camino Media, Suite 200, 93311 Bakersfield, USA

the Certificate No: **Z02180** for the PROFIBUS Master:

Model Name: P MEPXM0100
 Revision: 1.001; SW/FW: 1.001; HW: 1.3
 GSD: PSFT10F3.GSD, File Version: 4/11/2016

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0, Sync, Freeze, Fail_Safe, Set_Slave_Add, Autoclear
<input checked="" type="checkbox"/>	DP-V1	MS1 Read, MS1 Write, MS2 Initiate, MS2Abort, MS2 Read, MS2Write
<input checked="" type="checkbox"/>	Physical Layer	RS485

Test Report Number: MA016-1
 Authorized Test Laboratory: PROFI Interface Center, Johnson City, USA

The tests were executed in accordance with the following documents:
 "Test Specifications for PROFIBUS DP Masters, Version 3.0 from November 2005".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **October 31, 2021** the certificate is valid for life.

Karlsruhe, November 15, 2018

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)




(Dr. Jörg Hähnliche)