

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Hilscher

Gesellschaft für Systemautomation mbH

Rheinstr. 15

65795 Hattersheim, Germany

☒ Reference Implementation

The tested controller is a reference implementation of a Technology Component. Any controller using this implementation still needs to be certified with their own VendorID and DeviceID.

the Certificate No: **Z12351** for the PROFINET IO Controller:

Model Name: CIFX-90E

Order_Number: 1291.105

Identnumber: 0x011E; 0x0203

Revision: SW/FW: V3.3.0; HW: 1

This certificate confirms that the product has successfully passed the certification tests with the following scope:


<input checked="" type="checkbox"/> PNIO_Version	V2.35
<input checked="" type="checkbox"/> Conformance Class	B
	Optional features: Legacy, Topology, FSU, MRP
<input type="checkbox"/> Netload Class	III
<input checked="" type="checkbox"/> PNIO_Tester_Version	V2.35.2
<input checked="" type="checkbox"/> Tester	Siemens AG, Fürth, Germany, PNC73-1

This certificate is granted according to the document:

"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **October 12, 2021** the certificate is valid for life.

Karlsruhe, November 27, 2018



(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)




(Dr. Jörg Hähnliche)