

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

**SIEMENS AG, DI PA AE HWP PE**

Östliche Rheinbrückenstr. 50, 76187 Karlsruhe, Germany

the Certificate No: **Z13845** for the PROFINET IO Device:

Model Name: SIMATIC COMPACT FIELD UNIT CIO HART (CFU)  
 Revision: SW/FW: V1.0.0; HW: 0  
 Identnumber: 0x002A; 0x0319  
 GSD: GSDML-V2.43-Siemens-CFU-CIO-HART-20240304.xml  
 DAP: IDDAP\_CFU\_CIO\_HART, 0x53010000

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.43
<input checked="" type="checkbox"/> Conformance Class	B
<input checked="" type="checkbox"/> Optional Features	Legacy, MRP, System Redundancy (S2)
<input checked="" type="checkbox"/> Application Class	High Availability
<input checked="" type="checkbox"/> Netload Class	II
<input checked="" type="checkbox"/> PNIO_Tester_Version	Version V2.44.1.2 with annex spirta
<input checked="" type="checkbox"/> Tester	an testlabs, Prague, Czech Republic; PN 024-11 plus Manufacturer Declaration

This certificate is granted according to the document:  
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **March 18, 2027** the certificate is valid for life.

Karlsruhe, June 20, 2024

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)




(Xaver Schmidt)



(Frank Moritz)