PROFIBUS • PROFINET

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Molex
216 Bathurst Drive, N2V 1N3 Waterloo, Ontario, CANADA

the Certificate No: **Z01449** for the PROFIBUS Master:

Model Name:	**SST-PB3-CLX MASTER**
Revision:	**Rev 1.0; SW/FW: Rel 7.28; HW: Rev 1.0**
GSD:	**SSTM0C44.GSD, File Version: 18/09/09**

This certificate confirms that the product has successfully passed the certification tests with the following scope:

☑ **DP-V0**	MS0, Sync, Freeze, Fail_Safe, Mixed Master and DP-V0 Slave
☑ **DP-V1**	MS1, MS2
☑ **Physical Layer**	RS485

Test Report Number: **PIC MA011-2**
Authorized Test Laboratory: **PROFI Interface Center, Johnson City, USA**

The tests were executed in accordance with the following documents:
"Test Specifications for PROFIBUS DP Masters, Version 3.0 from November 2005".
This certificate is granted according to the document:
"Framework for testing and certification of PROFIBUS and PROFINET products".
For all products that are placed in circulation by August 24, 2015 the certificate is valid for life.

(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.

(Karsten Schneider)

(K.-P. Lindner)

PROFIBUS®