

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

Yokogawa Electric Corporation

2-9-32 Nakacho, Musashino-shi, Tokyo 180-8750, Japan

the Certificate No: **Z01070** for the PROFIBUS Device:

Model Name: DO202-P Disolved Ogygen transmitter

Revision: R3.01; SW/FW: R3.02; HW: R3.01

GSD: YP010786.gsd File Version 3.01 (03.July 2007)

PA139750.gsd

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0, Set_Slave_Add
<input checked="" type="checkbox"/>	DP-V1	MS2, I&M
<input checked="" type="checkbox"/>	Profiles	PA Devices V 3.01
<input checked="" type="checkbox"/>	Physical Layer	MBP

Test Report Number: **itm 656 PA 01/01**

Authorized Test Laboratory: **itm, München, Germany**

The tests were executed in accordance with the following documents:


"Test Specifications for PROFIBUS DP Slaves, Version 3.0 from November 2005" and

"Test Specifications for PA Devices, Profile 3.0, Version 4.1, November 2004".

This certificate is granted according to the document:

"Framework for testing and certification of PROFIBUS products".

For all products that are placed in circulation by July 18, 2016 the certificate is valid for life.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)

(K.-P. Lindner)