

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to  
**Mettler-Toledo AG, Process Analytics**  
**Im Hackacker 15, 8902 Urdorf, Switzerland**

the Certificate No: **Z00766** for the PROFIBUS Device:

**Model Name: Condi 7100 PA**  
**Revision: V 1.0; Stack 1.3 (09.12.98); SW: Version 2.0**  
**GSD: METT7533.gsd**  
**PA 139750.gsd**

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/>	DP-V0	MS0
<input checked="" type="checkbox"/>	DP-V1	MS2
<input checked="" type="checkbox"/>	Profile	PA Devices V 3.0
<input checked="" type="checkbox"/>	Physical Layer	MBP

**Test Report Number: 036-01**  
**Authorized Test Laboratory: ifak, Magdeburg, Germany**

The tests were executed in accordance with the following documents:  
 "Test Specifications for PROFIBUS DP Slaves from February 2000" and  
 "Test Specifications for Field Devices in accordance with PROFIBUS PA Profile Process Control  
 Devices Version 3.0 from April 2000".

This certificate is granted according to the document:  
 "Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by June 09, 2017 the certificate is valid for life.


Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)

(K.-P. Lindner)