

# Certificate

PROFIBUS Nutzerorganisation e.V. grants to

## SICK AG

Erwin-Sick-Str. 1, 79183 Waldkirch, Germany

the Certificate No: **Z01668** for the PROFIBUS Device:

Model Name: DL100-1x /2x  
Revision: 1.0; SW/FW: 2.01; HW: 1.00  
GSD: SICK0D34.GSD

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> DP-V0	MS0, Sync, Freeze
<input checked="" type="checkbox"/> Physical Layer	RS485

Test Report Number: PCN176-DPS-01  
Authorized Test Laboratory: PROCENTEC, Wateringen, The Netherlands

The tests were executed in accordance with the following documents:  
"Test Specifications for PROFIBUS DP Slaves, Version 3.0.9, September 2008".

This certificate is granted according to the document:  
"Framework for testing and certification of PROFIBUS and PROFINET products".

For all products that are placed in circulation by **February 13, 2025** the certificate is valid for life.

Karlsruhe, January 27, 2022

Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Karsten Schneider)



(Dr. Jörg Hähnliche)