

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

SIEMENS AG, DF FA AS DH CHE 2
Leipziger Str. 400, 09247 Chemnitz, Germany


the Certificate No: **Z10995** for the PROFINET IO Device:

Model Name: EK ERTEC200P V4.3
Revision: SW/FW: R43.0.10; HW: 2
Identnumber: 0x002a; 0x0008
GSD: GSDML-V2.31-Siemens-ERTEC200pEvalkit-20150225.XML
DAP: DAP3: Standard MRP; 0x00000003

This certificate confirms that the product has successfully passed the certification tests with the following scope:


<input checked="" type="checkbox"/>	PNIO_Version	V2.31
<input checked="" type="checkbox"/>	Conformance Class	C Optional Features: Legacy, Advanced, FSU, MRP, IRT
<input checked="" type="checkbox"/>	Application Class	Isochronous
<input checked="" type="checkbox"/>	Netload Class	III
<input checked="" type="checkbox"/>	PNIO_Tester_Version	V2.3.5
<input checked="" type="checkbox"/>	Tester	SIEMENS AG, Fürth, Germany PN332-1, IRT079-1

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".
 For all products that are placed in circulation by March 13, 2018 the certificate is valid for.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e.V.



(Karsten Schneider)

(K.-P. Lindner)