

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

SIEMENS AG, DF FA AS DH AMB 3

Werner-von-Siemens-Str. 50, 92224 Amberg, Germany

the Certificate No: **Z11127** for the PROFINET IO Device:

Model Name: CPU 1518-4 PN/DP
Revision: 6ES7 518-4AP00-0AB0; SW/FW: V1.8; FS: 01
Identnumber: 0x002a; 0x0114
GSD: GSDML-V2.31-#Siemens_CPU1500-1518-4PNDP_20150428-130000.XML
DAP: DAP 1, 0x00054322

This certificate confirms that the product has successfully passed the certification tests with the following scope:

<input checked="" type="checkbox"/> PNIO_Version	V2.32
<input checked="" type="checkbox"/> Conformance Class	C Optional features: Legacy, FSU, MRP, MRPD, IRT
<input checked="" type="checkbox"/> Netload Class	III
<input checked="" type="checkbox"/> PNIO_Tester_Version	V2.3.5
<input checked="" type="checkbox"/> Tester	SIEMENS AG, Fürth, Germany PN210-6, IRT043-5

This certificate is granted according to the document:


“Framework for testing and certification of PROFIBUS and PROFINET products”.

For all products that are placed in circulation by June 15, 2018 the certificate is valid for life.




(Official in Charge)

Board of PROFIBUS Nutzerorganisation e. V.



(Karsten Schneider)

(K.-P. Lindner)